

# APPENDIX I

---

## TRANSITION PLAN

## 3-YEAR TRANSITION PLAN

### PRIORITY 1 – APPROACH & ENTRANCE

| Area                    | Access Issue  | Solution  | Target Date      | Person Responsible              | Est. Cost |
|-------------------------|---|---|------------------|---------------------------------|-----------|
| Prosecutor's Office     | Accessible parking spaces in rear of building are not compliant.      | Send letter to the City of Tell City describing non-compliant issues, and request that compliance be made.  | By year-end 2018 | ADA Coordinator                 | \$0       |
| South Annex             | Main entrance is not accessible.                                      | Install ADA-compliant ramp, Accessible entrance signs, and accessible/van parking sign.   | By year-end 2019 | Commissioners & ADA Coordinator | \$8,000   |
| Armory Annex            | Additional accessible parking space needs to be added.                | Configure one additional accessible parking space next to existing accessible aisle at Health Department entrance – paint lines and install sign. | By year-end 2020 | Maintenance Supervisor          | \$100     |
| Multi Services Building | Accessible parking spaces are not configured properly.                | Paint lines and access aisle, and install van accessible sign.  | By year-end 2020 | Highway Superintendent          | \$100     |
| Eagles Bluff            | Van accessible space needs configured and lines need to be repainted. | Add van accessible sign and re-paint lines.   | By year-end 2020 | Parks and Recreation Director   | \$100     |
| Eagles Bluff            | Carpet floor mat needs to be secured to floor.                        | Secure floor mat to floor or install ADA-compliant mat.   | By year-end 2020 | Parks and Recreation Director   | \$100     |

**PRIORITY 2 – ACCESS TO GOODS AND SERVICES**

| <b>Area</b>             | <b>Access Issue</b>  | <b>Solution</b>  | <b>Target Date</b> | <b>Person Responsible</b> | <b>Est. Cost</b> |
|-------------------------|--|--|--------------------|---------------------------|------------------|
| Armory Annex            | Transaction counters at Health Department and Recycling Management are too high. | Alternative access to services may be made by entering through accessible office doorways. Departments will ensure that bells are placed on counters within the appropriate reach range. | By year-end 2018   | ADA Coordinator           | \$0              |
| Multi Services Building | Counter height is too high.  | Alternative access to services may be made by entering through accessible office doorway. Department will ensure that a bell is placed on counter within the appropriate reach range.    | By year-end 2018   | Highway Superintendent    | \$0              |
| Prosecutor's Office     | Counter height is too high.  | Alternative access to services may be made by entering through accessible office doorway. Department will ensure that a bell is placed on counter within the appropriate reach range.    | By year-end 2018   | ADA Coordinator           | \$0              |
| Courthouse              | Door closers throughout facility are not adjusted properly.                      | All door closers will be checked and adjusted to ensure compliance.  | By year-end 2019   | Maintenance Supervisor    | \$0              |
| Courthouse              | Operable parts need to be checked to ensure compliance.                          | Operable parts used by the public will be checked and noted if they are not within appropriate height.   | By year-end 2019   | Maintenance Supervisor    | \$0              |